

# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-US-2246818-1  
**Report Reference** E475420-20221130  
**Date** 6-Feb-2023

**Issued to:** LOYTEC electronics GmbH  
Blumengasse 35 Wien 1170  
Austria

**This is to certify that representative samples of** XACN - Miscellaneous Controls  
See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.


**Standard(s) for Safety:** UL 60730-1, 5th Ed., Issue Date: 2016-8-3, Revision Date: 2021-10-18

**Additional Information:** See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

  
Deborah Jennings-Conner, VP Regulatory Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-US-2246818-1  
**Report Reference** E475420-20221130  
**Date** 6-Feb-2023

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

<b>Model</b>	<b>Category Description</b>
LDALI-RM5	Automatic Electrical Controls
LDALI-RM6	Automatic Electrical Controls
LDALI-RM8	Automatic Electrical Controls

*Deborah Jennings-Conner*  
Deborah Jennings-Conner, VP Regulatory Services



UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>

# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-CA-2244600-1  
**Report Reference** E475420-20221130  
**Date** 6-Feb-2023

**Issued to:** LOYTEC electronics GmbH  
Blumengasse 35 Wien 1170  
Austria

**This is to certify that representative samples of** XACN7 - Miscellaneous Controls Certified for Canada  
See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** CAN/CSA E 60730-1:15, 5th Ed., AMD 2, Issue Date: 2015-12, Revision Date: 2021-10

**Additional Information:** See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

  
Deborah Jennings-Conner, VP Regulatory Services

UL LLC



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>



# CERTIFICATE OF COMPLIANCE

**Certificate Number** UL-CA-2244600-1  
**Report Reference** E475420-20221130  
**Date** 6-Feb-2023

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

<b>Model</b>	<b>Category Description</b>
LDALI-RM5	Automatic Electrical Controls
LDALI-RM6	Automatic Electrical Controls
LDALI-RM8	Automatic Electrical Controls

*Deborah Jennings-Conner*  
Deborah Jennings-Conner, VP Regulatory Services



UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>